

Temperature Options

- HT – Hydrostatic test ASTM-E-1003-95 and certificate.
- XR – X-ray inspection test and certificate.
- PI – Positive material identification test (PMI) and certificate
- DY – Dye penetrans test ASTM-E-1220-05 and certificate
- NT – Hardness test and certificate
- TC – Thermo element and transmitter signal calibration, 5 different valves and certificate
- FE – Thermo element and transmitter signal calibration at specific values, graphics, and hysteresis included.
- EQ - Isolation and signal quality test and certificate.
- TC –Prefabricated section 2"-24" flanged ends or bevel ends with thermowell.
- IP – Full penetration flange welding.
- DP –Temperature transmitter (Hart protocol communication).
- PC – PTFE coated.
- WT – Welding treatment and certificate.
- AC – Abrasive coated.
- AT – Additional stamps characters (standard KKS or TAG, material on thermo well) (standard KKS or TAG, element type on temperature element).
- SD – Special project requirements.